



THE CITY OF NEW YORK
DEPARTMENT OF BUILDINGS
<http://www.nyc.gov/buildings>

X
MANHATTAN (1)
 280 BROADWAY 3RD FLOOR
 New York, NY 10007

BRONX (2)
 1932 ARTHUR AVENUE
 BRONX, NY 10457

BROOKLYN (3)
 210 JORELOMON STREET
 BROOKLYN, NY 11201

QUEENS (4)
 120-55 QUEENS BLVD.
 QUEENS, NY 11424

STATEN ISLAND (5)
 BORO HALL- ST. GEORGE
 STATEN ISLAND, NY 10301

DOB Application # 122707400	Examiner:.....GINIO TOPINO	Date... 03/24/2016
	Application Type:....SIGN	Doc (s): 01
	Address / Location....1701 BROADWAY	Block... 1025
	Zoning District... .. C6-2	Lot..... 44
	Multiple Dwell Classification:	

Examiners Signature:

To discuss and resolve these objections, please call 311 to schedule an appointment with the Plan Examiner listed above. You will need the application number and document number found at the top of this objection sheet. To make the best possible use of the plan examiners and your time, please make sure you are prepared to discuss and resolve these objections before your scheduled plan exam appointment.

	Doc #	Section of Code	Objections	Date Resolved	Comments
1.			All new Signs must comply with 2008 Building Code.		
2.			Also provide Sign Hanger Certification Form		
3.			Sign will not block any windows, doors and fire escape.		
4.			Show compliance with ZR 32-66 on PW1 form and on drawing to verify whether the sign is not within certain distance of an arterial highway or park.		
5.			Provide structural sign application.		
6.			Also indicate max projection of sign from the wall.		
7.			Correct the height of the sign on PW-1 from; application show 35'-0" but the dwgs show 42'-0" above the sidewalk.		